


# **Electrical Specifications**

LED120A0350C28FO			
Brand Name	XITANIUM		
Driver Type	Electronic		
Input Voltage	120		
Input Frequency	50/60Hz		
RoHS	No		
Approbations	UL, CSA		
Status	Active		

Max.			Operating	Input	Max.						
Output Power (W)	Output Voltage (V)	Output Current (A)	Temp. Range (°F/°C)	Current at I20V (A)	Input Power (W)	Inrush Current (A <sub>pk</sub> /µs)	Max. THD (%)	Min. Power Factor	Surge Protection (KV)	Weight (Lbs)	Envir. Protection Rating
10	2.8~28.0	0.35	-40°~140°F (-40~60°C)	0.10	12.5	-	20	0.9	2.0	0.3/135	UL Dry & Damp



Input, Output and 0-10V Dimming use lead-wires. Lead-wires are 18AWG 105C/600V solid copper


Standard Lead Lenath

Revised 05/16/2012

<del> </del>					
in.	cm.				
6	15				
6	15				
6	15				
6	15				
	6 6				

## Maximum Wiring Distance (at full load)

Wire Size (AWG)	Distance
	(feet)
26	16
24	26
22	43
20	68
18	108
16	170
14	275
12	420
10	714







UL Class 2 E220165 7310\_S-000 3426-32

PHILIPS LIGHTING ELECTRONICS N.A.



LED120A0350C28FO				
Brand Name	XITANIUM			
Driver Type	Electronic			
Input Voltage	120			
Input Frequency	50/60Hz			
RoHS	No			
Approbations	UL, CSA			
Status	Active			

## Installation & Application Notes:

### Section I – Physical Characteristics

- 1.1 LED Driver shall be installed inside an electrical enclosure.
- 1.2 Wiring inside electrical enclosure shall comply with 600V/105°C rating or higher.

#### Section II – Performance

- 2.1 LED Driver is UL Class 2 power unit as per UL879 & UL1310. It is also listed in the UL Sign Accessory Manual.
- 2.2 LED Driver is certified by UL for use in a dry or damp location (Outdoor Type I).
- 2.3 LED Driver has Class A sound rating.
- 2.4 LED Driver tolerates sustained open circuit and short circuit output conditions without damage.
- 2.5 LED Driver maximum allowable case temperature is 90°C see product label for measurement location.
- 2.6 LED Driver complies with FCC rules and regulations, as per Title 47 CFR Part 15 Non-Consumer (Class A) for EMI/RFI (conducted and radiated) at full load.

### Section III – UL Conditions of Acceptability (File E220165)

When installed in the end product, consideration shall be given to the following:

- 3.1 This component has been judged in the basis of the required spacing in the standard for Electric Sign Component, UL 879, Eighth Edition, which would cover the component itself if submitted for Listing.
- 3.2 This unit is provided with a Class 105(a) insulation system.
- 3.3 The unit is intended for installation inside an electrical enclosure.
- 3.4 The unit was submitted and tested for a maximum manufacturer's recommended ambient (Tmra) of 40°C. If adjacent LED power supplies are spaced closer than 1 in. end to end or 4 in. side to side a temperature test shall be conducted in the end use product.
- 3.5 The ground connection is not suitable as the equipment ground for a sign. Separate provision for sign grounding must be provided.

#### **Revision History:**

Rev No.	Date	Description	Approval	Remarks
1.1	01/16/2012	* Add Envir. Protection Rating	N.T.	
1.2	03/02/2012	*Modify Part #(Remove Dashes)	N.T.	
1.3	05/16/2012	*Add Approbations: UL, CSA	N.T.	